

台灣自來水股份有限公司 第一區管理處水質課 大水樣(一般檢項)檢測報告

期間 114/4/1 至 114/4/30 第 1 頁共 2 頁

採樣日期				受檢單位		水樣別	天氣		氣溫(℃)	水溫(℃)	濁度(NTU)	色度(鉑鈷單位)	臭度(初嗅數)	總鹼度	pH值	氯鹽	硫酸鹽	氟鹽	氨氮	亞硝酸鹽氮	硝酸鹽氮	總溶解固體量	自由有效餘氯	總硬度	鐵	錳	鋁	導電度(μS/cm)	糞便性大腸桿菌群(CFU/100mL)	大腸桿菌群(CFU/100mL)	總菌落數(CFU/mL)	陰離子界面活性劑	化學需氧量	懸浮固體量	備註
年	月	日	廠所	淨水場	前日		當日																												
飲用水水源水質標準									-	-	-	-	-	-	-	-	-	-	1	-	-	-	-	-	-	-	-	-	-	20000	-	-	25	-	
飲用水水質標準									-	-	2	5	3	-	6.0-8.5	250	250	0.8	0.1	0.1	10.0	500	0.2-1.0	300	0.3	0.05	0.2	-	-	6	100	0.5	-	-	
114	4	7	文山	石碇	原水	雨	晴	22.5	19.3	1.8	6	<1	46.4	8.1	6.37	11.1	0.05	0.05	ND	0.70	99.0	-	43.1	0.064	0.008	0.101	136	-	1.4E+03	1.7E+03	-	6.3	1.3	-	
2501066310																																			
114	4	7	文山	石碇	清水	雨	晴	22.5	18.5	0.45	<5	<1	46.4	7.8	7.41	10.9	0.05	ND	ND	0.78	101	0.58	42.2	0.048	ND	0.070	138	-	<1	<1	ND	-	-	-	
2501066311																																			
114	4	7	文山	坪林	原水	雨	晴	25.5	18.7	9.2	5	<1	17.5	7.8	6.18	7.70	0.03	0.04	ND	0.57	55.0	-	19.6	0.197	0.015	0.160	76	-	5.0E+02	5.5E+02	-	ND	-	-	
2501066320																																			
114	4	7	文山	坪林	清水	雨	晴	25.5	18.7	0.20	<5	<1	18.6	7.6	6.98	7.85	0.03	ND	ND	0.62	55.0	0.64	19.6	0.078	ND	0.073	79	-	<1	<1	ND	-	-	-	
2501066321																																			
114	4	7	文山	烏來	原水	雨	晴	23.0	18.6	0.65	5	<1	26.8	7.9	2.80	10.7	0.06	0.03	ND	0.34	63.0	-	27.5	0.016	ND	0.024	86	-	6.0E+02	2.0E+03	-	4.3	-	-	
2501066330																																			
114	4	7	文山	烏來	清水	雨	晴	23.0	18.1	0.30	<5	<1	26.8	7.7	3.55	10.6	0.05	ND	ND	0.38	55.0	0.52	28.4	0.008	ND	0.045	87	-	<1	<1	ND	-	-	-	
2501066331																																			
114	4	7	文山	平溪	原水	雨	晴	22.0	19.1	2.0	5	<1	26.8	8.3	6.45	7.15	0.03	0.09	ND	0.26	60.0	-	25.5	0.068	ND	0.057	89	-	9.5E+02	1.2E+03	-	ND	1.3	-	
2501066340																																			
114	4	7	文山	平溪	清水	雨	晴	22.0	20.1	0.20	<5	<1	25.8	7.7	7.51	6.77	0.03	0.02	ND	0.32	65.0	0.41	25.5	0.053	ND	0.083	88	-	<1	<1	ND	-	-	-	
2501066341																																			
114	4	7	新山	暖暖	原水	雨	晴	25.5	18.4	4.6	6	<1	12.4	7.3	9.58	5.82	0.02	0.04	ND	0.67	60.0	-	13.7	0.160	0.032	0.115	75	<10	1.5E+02	1.6E+02	-	4.3	2.5	-	
2501066230																																			
114	4	7	新山	暖暖	清水	雨	晴	25.5	18.5	0.25	<5	<1	14.4	7.2	12.1	5.97	ND	ND	ND	0.67	59.0	0.77	13.7	0.015	ND	0.061	85	<1	<1	<1	ND	-	-	-	
2501066231																																			
114	4	7	新山	安樂	原水	雨	晴	23.1	18.0	4.0	5	<1	33.0	7.8	10.6	6.65	0.02	0.04	ND	0.70	82.0	-	33.3	0.160	0.013	0.120	114	-	7.5E+02	7.8E+02	-	3.8	3.6	-	
2501066250																																			
MDL														0.40	0.38	0.02	0.02	0.02	0.05		0.03	2.0	0.007	0.006	0.008				0.03	3.8					
備註																	QL=0.05							QL=0.020	QL=0.020	QL=0.020									

備註:

台灣自來水股份有限公司 第一區管理處水質課 大水樣(一般檢項)檢測報告

期間 114/4/1 至 114/4/30 第 2 頁共 2 頁

採樣日期				受檢單位		水樣別	天氣		氣溫(℃)	水溫(℃)	濁度(NTU)	色度(鉑鈷單位)	臭度(初嗅數)	總鹼度	pH值	氯鹽	硫酸鹽	氟鹽	氨氮	亞硝酸鹽氮	硝酸鹽氮	總溶解固體量	自由有效餘氯	總硬度	鐵	錳	鋁	導電度(μS/cm)	糞便性大腸桿菌群(CFU/100mL)	大腸桿菌群(CFU/100mL)	總菌落數(CFU/mL)	陰離子界面活性劑	化學需氧量	懸浮固體量	備註
年	月	日	廠所	淨水場	前日		當日																												
飲用水水源水質標準									-	-	-	-	-	-	-	-	-	1	-	-	-	-	-	-	-	-	-	-	20000	-	-	25	-	-	
飲用水水質標準									-	-	2	5	3	-	6.0-8.5	250	250	0.8	0.1	0.1	10.0	500	0.2-1.0	300	0.3	0.05	0.2	-	-	6	100	0.5	-	-	-
114	4	7	新山	安樂	清水	雨	晴	23.1	19.1	0.25	<5	<1	30.9	7.6	13.0	6.94	0.02	ND	ND	0.71	89.0	0.59	33.3	ND	ND	0.066	121	-	<1	<1	ND	-	-	-	
			2501066251																																
114	4	7	新山	新山	原水	雨	晴	27.0	19.3	3.0	8	<1	43.3	7.5	12.2	17.3	0.04	0.10	0.08	1.12	104	-	45.1	0.161	0.026	0.247	166	25	9.0E+03	9.2E+03	-	13.8	4.3	-	
			2501066240																																
114	4	7	新山	新山	清水	雨	晴	27.0	19.5	0.25	<5	<1	37.1	7.4	16.0	16.8	0.04	0.02	ND	1.01	119	0.42	43.1	ND	ND	0.032	165	<1	<1	<1	ND	-	-	-	
			2501066241																																
114	4	7	新山	六堵	原水	雨	晴	21.7	17.8	1.8	6	<1	28.9	7.9	13.3	11.9	0.02	0.04	ND	0.73	105	-	33.3	0.068	ND	0.091	131	-	1.2E+03	1.3E+03	-	4.2	1.3	-	
			2501066270																																
114	4	7	新山	六堵	清水	雨	晴	21.7	18.0	0.25	<5	<1	27.8	7.3	15.5	12.5	0.02	0.02	ND	0.78	95.0	0.48	33.3	ND	ND	0.046	139	-	<1	<1	0.09	-	-	-	
			2501066271																																
114	4	7	新山	八堵抽水站	原水	雨	晴	25.8	20.1	4.2	10	<1	47.4	7.9	12.8	19.2	0.05	0.40	0.07	1.00	99.0	-	50.0	0.142	0.038	0.050	172	-	7.5E+03	7.7E+03	-	14.6	-	-	
			2501066290																																
				以下空白																															
																								</											

備註:

台灣自來水股份有限公司 第一區管理處水質課 大水樣(一般檢項)檢測報告

單位：毫克／公升(mg/L)				期間																	114/5/1		至		114/5/31																	第 1		頁共 2		頁	
採樣日期				受檢單位		水樣別	天氣		氣溫(℃)	水溫(℃)	濁度(NTU)	色度(鉑銨單位)	臭度(初嗅數)	總鹼度	pH值	氯鹽	硫酸鹽	氟鹽	氨氮	亞硝酸鹽氮	硝酸鹽氮	總溶解固體量	自由有效餘氯	總硬度	鐵	錳	鋁	導電度(μS/cm)	糞便性大腸桿菌群(CFU/100mL)	大腸桿菌群(CFU/100mL)	總菌落數(CFU/mL)	陰離子界面活性劑	化學需氧量	懸浮固體量	備註												
年	月	日	廠所	淨水場	前日		當日																																								
飲用水水源水質標準									-	-	-	-	-	-	-	-	-	-	1	-	-	-	-	-	-	-	-	-	-	-	20000	-	-	25	-												
飲用水水質標準									-	-	2	5	3	-	6.0-8.5	250	250	0.8	0.1	0.1	10.0	500	0.2-1.0	300	0.3	0.05	0.2	-	-	6	100	0.5	-	-													
114	5	5	瑞芳	員山	原水	陰	陰	29.0	25.6	1.8	9	<1	51.2	8.5	9.48	21.2	0.05	0.02	ND	0.37	88.0	-	48.3	0.138	0.017	0.209	173	1.9E+02	4.2E+03	1.2E+03	-	8.6	11.1	-													
			2501066700																																												
114	5	5	瑞芳	員山	清水	陰	陰	29.0	24.4	0.80	<5	<1	49.2	8.0	11.9	19.6	0.05	ND	ND	0.41	107	0.60	46.3	0.062	0.008	0.079	174	<1	<1	<1	ND	-	-	-													
			2501066701																																												
114	5	5	汐止	白雲	原水	陰	陰	29.2	22.7	2.3	5	<1	29.7	8.0	8.44	8.61	0.04	0.04	ND	0.48	82.0	-	31.5	0.056	ND	0.153	105	-	2.4E+03	1.7E+03	-	4.8	-	-													
			2501066710																																												
114	5	5	汐止	白雲	清水	陰	陰	29.2	22.9	0.20	<5	<1	28.7	7.7	8.71	8.61	0.04	ND	ND	0.48	84.0	0.55	29.6	0.010	ND	0.039	107	-	<1	<1	ND	-	-	-													
			2501066711																																												
114	5	5	淡水	北投子	原水	陰	陰	24.5	22.2	0.20	<5	<1	81.9	6.6	15.4	6.26	0.05	0.03	ND	3.65	161	-	81.8	0.036	ND	0.034	243	-	5	20	-	ND	-	-													
			2501066820																																												
114	5	5	淡水	北投子	清水	陰	陰	24.5	23.6	0.20	<5	<1	80.9	6.6	16.2	6.28	0.05	ND	ND	3.66	186	0.52	82.8	0.016	ND	0.032	247	-	<1	<1	ND	-	-	-													
			2501066821																																												
114	5	5	淡水	老梅	原水	陰	陰	26.0	21.8	1.3	5	<1	24.6	7.8	10.1	4.15	ND	0.03	ND	0.83	63.0	-	25.6	0.076	ND	0.100	97	-	4.0E+03	2.1E+03	-	7.2	3.6	-													
			2501066830																																												
114	5	5	淡水	老梅	清水	陰	陰	26.0	22.4	0.35	<5	<1	26.6	7.7	11.0	4.11	ND	ND	ND	0.83	72.0	0.60	25.6	0.034	ND	0.135	101	-	<1	<1	ND	-	-	-													
			2501066831																																												
114	5	5	淡水	樹興	原水	陰	陰	25.0	19.5	1.0	<5	<1	34.8	7.9	7.75	5.61	0.03	0.04	ND	0.58	76.0	-	33.5	0.031	ND	0.173	110	-	1.7E+02	87	-	ND	-	-													
			2501066850																																												
114	5	5	淡水	樹興	清水	陰	陰	25.0	22.0	0.35	<5	<1	35.8	7.9	9.25	5.67	0.03	ND	ND	0.50	67.0	0.43	34.5	0.065	ND	0.107	116	-	<1	<1	ND	-	-	-													
			2501066851																																												
114	5	5	淡水	興華	原水	陰	陰	26.0	20.6	0.80	<5	<1	34.8	7.8	7.65	5.51	0.03	0.04	ND	0.58	82.0	-	34.5	0.038	ND	0.196	110	-	1.9E+02	92	-	ND	-	-													
			2501066860																																												
MDL															0.40	0.38	0.02	0.02	0.02	0.05		0.03	2.0	0.007	0.006	0.008					0.03	3.8															
備註																		QL=0.05							QL=0.020	QL=0.020																					

備註:

台灣自來水股份有限公司 第一區管理處水質課 大水樣(一般檢項)檢測報告

期間 114/6/1 至 114/6/30 第 1 頁共 1 頁

採樣日期				受檢單位		水樣別	天氣		氣溫(℃)	水溫(℃)	濁度(NTU)	色度(鉑鈷單位)	臭度(初嗅數)	總鹼度	pH值	氯鹽	硫酸鹽	氟鹽	氨氮	亞硝酸鹽氮	硝酸鹽氮	總溶解固體量	自由有效餘氯	總硬度	鐵	錳	鋁	導電度(μS/cm)	糞便性大腸桿菌群(CFU/100mL)	大腸桿菌群(CFU/100mL)	總菌落數(CFU/mL)	陰離子界面活性劑	化學需氧量	懸浮固體量	備註																										
年	月	日	廠所	淨水場	前日		當日																																																						
飲用水水源水質標準							-	-																												-	-	-	-	-	-	1	-	-	-	-	-	-	-	-	-	-	-	-	20000	-	-	25	-		
飲用水水質標準							-	-																												2	5	3	-	6.0-8.5	250	250	0.8	0.1	0.1	10.0	500	0.2-1.0	300	0.3	0.05	0.2	-	-	6	100	0.5	-	-		
114	6	2	萬金	萬里	原水	晴	晴	31.5	20.8	1.2	<5	<1	55.3	7.0	15.3	4.61	0.02	0.04	ND	0.98	123	-	51.0	0.117	ND	0.074	171	-	27	84	-	ND	-	-																											
2501067010																																																													
114	6	2	萬金	萬里	清水	晴	晴	31.5	21.0	0.25	<5	<1	54.3	7.1	15.8	4.65	0.02	ND	ND	0.98	132	0.40	51.0	0.007	ND	0.025	173	-	<1	<1	ND	-	-	-																											
2501067011																																																													
114	6	2	萬金	林莊	原水	晴	晴	31.0	21.2	1.4	<5	<1	30.2	7.9	7.20	6.07	ND	0.08	ND	0.59	65.0	-	30.8	0.063	ND	0.078	100	-	5.0E+02	2.0E+02	-	4.2	-	-																											
2501067020																																																													
114	6	2	萬金	林莊	清水	晴	晴	31.0	21.4	0.25	<5	<1	30.2	7.8	8.32	6.11	ND	0.02	ND	0.60	76.0	0.67	29.8	0.032	ND	0.065	104	-	<1	<1	ND	-	-	-																											
2501067021																																																													
114	6	2	萬金	中幅	原水	晴	晴	30.7	23.0	23	20	<1	31.2	7.6	12.5	6.75	0.02	0.03	ND	0.73	75.0	-	29.8	0.112	0.013	0.111	116	-	4.6E+02	1.7E+02	-	8.9	3.3	-																											
2501067030																																																													
114	6	2	萬金	中幅	清水	晴	晴	30.7	24.4	0.45	<5	<1	30.2	7.2	11.0	7.05	0.02	0.02	ND	0.64	71.0	0.47	30.8	0.040	ND	0.094	120	-	<1	<1	ND	-	-	-																											
2501067031																																																													
114	6	2	萬金	二坪	原水	晴	晴	30.5	20.7	0.25	<5	<1	29.2	6.5	10.7	5.55	0.03	0.04	ND	1.17	93.0	-	31.7	ND	ND	0.014	113	-	19	80	-	ND	-	-																											
2501067040																																																													
114	6	2	萬金	二坪	清水	晴	晴	30.7	22.8	0.20	<5	<1	27.2	6.4	10.9	5.41	0.03	ND	ND	1.16	83.0	0.43	30.8	ND	ND	0.013	111	-	<1	<1	ND	-	-	-																											
2501067041																																																													
				以下空白																																																									
MDL														0.40	0.38	0.02	0.02	0.02	0.05		0.03	2.0	0.007	0.006	0.008					0.03	3.8																														
備註																	QL=0.05							QL=0.020	QL=0.020	QL=0.020																																			

備註: